BSI-Inspectorate America 178 Mortland Road Searsport, Maine 04974 (207)548-6440



QUALITY CERTIFICATE

Vessel SHORE TA

Customer

Operation

SHORE TANK NO. 1

SPRAGUE

ANALYSIS

Port Date SEARSPORT, MAINE

October 25, 2005

Terminal SPRAGUE

Report SP/05/1023

Reference V-05-01531 Sample # 239079

Name of material being tested Description of sample source Samples Drawn by (company)

Samples Tested by (company)

NO. 6 FUEL OIL 0.5%

EX. SHORE TK NO. 1 AFTER DISCHARGE OF B NO. 235
INSPECTORATE
INSPECTORATE

Tests being Performed	Test method	Minimum	Maximum	Sample Source
GRAVITY, API @ 60 F FLASH POINT, F VISCOSITY, SSF @ 122 F POUR POINT, F WATER & SEDIMENT, % VOL. SULPHUR, % WT	ASTM D 4052 ASTM D 93 ASTM D 445/2161 ASTM D 97 ASTM D 1796 ASTM D 4294 ASTM D 482 AA/AE AA/AE CALCULATION			13.5 200 + 114.4 +59 0.05 0.437 0.04 18 11
BTU'S/GALLON NITROGEN, % WT. CARBON RESIDUE, % WT. ASPHALTENES, % WT.	CONVERSION ASTM D 5762 ASTM D 4530 IP-143			151,479 0.3262 6.75 1.20
SPRAGUE PROVIDES THE ATTACHED INSPECTION REPORT/ANALYSIS REPRESENTING THE SPECIFICATIONS OF THE PRODUCT AT THE SPRAGUE TERMINAL IN TANK ON THE DATE OF INSPECTION NOTED ON THE CERTIFICATE. THIS ANALYSIS IS PROVIDED TO THE CUSTOMER FOR THE PURPOSE OF ESTABLISHING THE INDEPENDENTLY VERIFIED PRODUCT SPECIFICATION ON A COMPOSITE BASIS IN SPRAGUE'S TERMINAL SHORE TANK AS NOTED ON THE CERTIFICATE. THE INSPECTION REPORT IS NOT TO BE USED FOR ANY OTHER PURPOSE. SPRAGUE DISCLAIMS ANY LIABILITY FOR THE PRODUCT AFTER DELIVERY BY SPRAGUE TO CUSTOMER. SPRAGUE DISCLAIMS ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR AN INTENDED USE EXCEPT AS MAY BE SPECIFICALLY SET FORTH IN WRITING IN ANY CONTRACT OR TERMS OF SALE BETWEEN SPRAGUE AND A BUYER OF PRODUCT. SPRAGUE ASSUMES NO LIABILITY FOR CLAIMS OR LOSSES THAT MAY ARISE FROM CUSTOMERS USE OF THIS INSPECTION REPORT/ANALYSIS.				

DENNIS E. CURTIS

Inspectorate America Corp (Searsport, Me.)